## SFUND RECORDS CTR 88172092



SEUND RECORDS CTR 2807-91921



CITY OF MOUNTAIN VIEW MOUNTAIN VIEW, CALIFORNIA 94042

Department

Public Works Waste Water Division Industrial Wastes Sampling

Date: February 28, 1979

Raytheon 415 East Middlefield Road Hountain View, California 94043

Attention: Plant Manager

Gentlemen:

-- SEWAGE VIOLATION NOTICE ---

A sample of the liquid industrial waste being discharged into the City of Mountain View's sewer system by your operations on February 22, 1979 at showed a pH value of 2.0 07:50

\_\_concentration can seriously interfere with waste treat= Any such acid ment processes at the sewage treatment plant and could give cause for the liability for the expense of re-establishing bacteriological processes.

Section 35.32.10 of the City Code has set acceptable limits for pH between 5.5 and 10.0 with a value of 7.0 being considered neutral. In view of the seriousness of this type violation, it is requested that corrective action be taken immediately.

When required by the Director of Public Works, measurements, tests and analyses of the characteristics of wastes shall be made at the expense of the discharger. You may be requested to pay for an analysis at any time that the quality of your industrial wastes is known or suspected to be in violation of the provision of City Code Section 35.32.

Sincerely,

CITY OF MOUNTAIN VIEW

erry W. Paulk Waste Water Superintendent

JWP: jo

PW-31 (Rev. 9/77) 540 CASTRO STREET . PHONE 967-7211

U87